

Central Laboratories Department
Food Laboratory Section

إدارة المختبرات المركزية
قسم مختبر الأغذية

Analysis Report

Ref No	F2303393	Received Date	26/04/2023	Date of Issue	02/05/2023
--------	----------	---------------	------------	---------------	------------

Customer & Sample Details

Name :	City Private School	
Source :	City Private School	Certificate No. :
Sample :	Drinking Water	Sampling by : معاذ محمد راشد الشحي
Description :	Primary Section	Packaging Type:
Brand :		Origin : Ajman
Net wt/volume per unit : /		Prod.Date :
Reason of Analysis :	School Survey	Exp.Date :
Remarks :	Ajman - Contact No: 0523117240	

Test Result

Parameter	Method	Result	Unit	Accept. Range	Remarks
MICROBIOLOGICAL					
Coliform Bacteria	IDEXX system				Not Detect
E.coli	IDEXX system	Not Detected			
Pseudomonas aeruginosa	IDEXX system	Not Detected			

Satisfactory

CHEMICAL RESULTS

Parameter	Method	Result	Unit	Accept. Range	Remarks
Free Chlorine		< 0.2	ppm		
Conductivity	FEL:SOP-02	205	us/cm		
TDS		123	mg/L	(100-1000)	
pH	FEL:SOP-01	7.5		6.5 - 8.5	
Bromate		< 5	ppb	=<10	

Satisfactory

Final Result: Investigated Parameters are Compliant with Regulations/Standards

General Comments

Note :

- The above result related only to the sample received by the Laboratory.
- This report shall not be reproduced except in full without approval from the Laboratory.
- This report is valid for three months from date of issue.
- The Final Conclusion is based on the overall Test Results Which mentioned in report only.

Page.No : 1 / 1

End Of Report



Head of Food Lab.



